

## PERMIT APPLICATION

# NY State Unified Solar Permit

Unified solar permitting is available statewide for eligible solar photovoltaic (PV) installations. Municipal authorities that adopt the unified permit streamline their process while providing consistent and thorough review of solar PV permitting applications and installations. Upon approval of this application and supporting documentation, the authority having jurisdiction (AHJ) will issue a building and/or electrical permit for the solar PV installation described herein.

### PROJECT ELIGIBILITY FOR UNIFIED PERMITTING PROCESS

By submitting this application, the applicant attests that the proposed project meets the established eligibility criteria for the unified permitting process (subject to verification by the AHJ). The proposed solar PV system installation:

- |                              |                             |                                                                                                                                                                                                                                           |
|------------------------------|-----------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 1. Has a rated DC capacity of 25 kW or less.                                                                                                                                                                                              |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 2. Is not subject to review by an Architectural or Historical Review Board. (If review has already been issued answer YES and attach a copy)                                                                                              |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 3. Does not need a zoning variance or special use permit.<br>(If variance or permit has already been issued answer YES and attach a copy)                                                                                                 |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 4. Is mounted on a permitted roof structure, on a legal accessory structure, or ground mounted on the applicant's property. If on a legal accessory structure, a diagram showing existing electrical connection to structure is attached. |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 5. The Solar Installation Contractor complies with all licensing and other requirements of the jurisdiction and the State.                                                                                                                |
| <input type="checkbox"/> Yes | <input type="checkbox"/> No | 6. If the structure is a sloped roof, solar panels are mounted parallel to the roof surface.                                                                                                                                              |

For solar PV systems not meeting these eligibility criteria, the applicant is not eligible for the Unified Solar Permit and must submit conventional permit applications. Permit applications may be downloaded here: [www.townofguilderland.org](http://www.townofguilderland.org) or obtained in person at **5209 Western Turnpike, Altamont NY 12009** during business hours **9am to 4:30 pm, Monday through Friday**.

### SUBMITTAL INSTRUCTIONS

For projects meeting the eligibility criteria, this application and the following attachments will constitute the Unified Solar Permitting package.

- This application form, with all fields completed and bearing relevant signatures.
- Permitting fee **based on the value of the installation**, payable by **Cash or Check, Made Payable to Town of Guilderland**.
- Required Construction Documents for the solar PV system type being installed, including required attachments.

Completed permit applications can be submitted in person at **5209 Western Turnpike, Altamont NY 12009** during business hours **9am to 4:30 pm, Monday through Friday**.

### APPLICATION REVIEW TIMELINE

Permit determinations will be issued within **14** calendar days upon receipt of complete and accurate applications. The municipality will provide feedback within **3** calendar days of receiving incomplete or inaccurate applications.

### FOR FURTHER INFORMATION

Questions about this permitting process may be directed to **the Guilderland Building Department at 518-356-1980**.

## PROPERTY OWNER

Property Owner's First Name

Last Name

Title

Property Address

City

State

Zip

Section

Block

Lot Number

## EXISTING USE

☐ Single Family

☐ 2-4 Family

☐ Commercial

☐ Other

## PROVIDE THE TOTAL SYSTEM CAPACITY RATING (SUM OF ALL PANELS)

Solar PV System: \_\_\_\_\_ kW DC

## SELECT SYSTEM CONFIGURATION

Make sure your selection matches the Construction Documents included with this application.

☐ Supply side connection with microinverters

☐ Load side connection with DC optimizers

☐ Supply side connection with DC optimizers

☐ Load side connection with microinverters

☐ Supply side connection with string inverter

☐ Load side connection with string inverter

## SOLAR INSTALLATION CONTRACTOR

Contractor Business Name

Contractor Business Address

City

State

Zip

Contractor Contact Name

Phone Number

Contractor License Number(s)

Contractor Email

Electrician Business Name

Electrician Business Address

City

State

Zip

Electrician Contact Name

Phone Number

Electrician License Number(s)

Electrician Email

Please sign below to affirm that all answers are correct and that you have met all the conditions and requirements to submit a unified solar permit.

Property Owner's Signature

Date

Solar Installation Company Representative Signature

Date

## SUBMITTAL REQUIREMENTS SOLAR PV 25KW OR LESS (ATTACHMENTS)

# NY State Unified Solar Permit

This information bulletin is published to guide applicants through the unified solar PV permitting process for solar photovoltaic (PV) projects 25 kW in size or smaller. This bulletin provides information about submittal requirements for plan review, required fees, and inspections.

*Note: Language in [ALL CAPS] below indicates where local jurisdictions need to provide information specific to the jurisdiction. Language in italics indicates explanatory notes from the authors of this document that may be deleted from the distributed version.*

### PERMITS AND APPROVALS REQUIRED

The following permits are required to install a solar PV system with a nameplate DC power output of 25 kW or less:

- a) Unified Solar Permit
- b) **BUILDING PERMIT.** Planning review **[IS NOT]** required for solar PV installations of this size.

Fire Department approval **IS NOT** required for solar PV installations of this size.

### SUBMITTAL REQUIREMENTS

In order to submit a complete permit application for a new solar PV system, the applicant must include:

- a) Completed Standard Permit Application form which includes confirmed eligibility for the Unified Solar Permitting process. This permit application form can be downloaded at [www.townofguilderland.org](http://www.townofguilderland.org).
- b) Construction Documents, with listed attachments **SAMPLES ARE AVAILABLE IN Understanding Solar PV Permitting and Inspecting in New York State** [www.townofguilderland.org](http://www.townofguilderland.org). Construction Documents must be stamped and signed by a New York State Registered Architect or New York State Licensed Professional Engineer.

**The Town of Guilderland**, through adopting the Unified Solar Permitting process, requires contractors to provide construction documents, such as the examples included in the Understanding Solar PV Permitting and Inspecting in New York State document. Should the applicant wish to submit Construction Documents in another format, ensure that the submittal includes the following information:

- Manufacturer/model number/quantity of solar PV modules and inverter(s).
- String configuration for solar PV array, clearly indicating the number of modules in series and strings in parallel (if applicable).
- Combiner boxes: Manufacturer, model number, NEMA rating.
- From array to the point of interconnection with existing (or new) electrical distribution equipment: identification of all raceways (conduit, boxes, fittings, etc.), conductors and cable assemblies, including size and type of raceways, conductors, and cable assemblies.
- Sizing and location of the EGC (equipment grounding conductor).
- Sizing and location of GEC (grounding electrode conductor, if applicable).
- Disconnecting means of both AC and DC including indication of voltage, ampere, and NEMA rating.
- Interconnection type/location (supply side or load side connection)
- For supply side connections only, indication that breaker or disconnect meets or exceeds available utility fault current rating KAIC (amps interrupting capacity in thousands).
- Ratings of service entrance conductors (size insulation type AL or CU), proposed service disconnect, and overcurrent protection device for new supply side connected solar PV system (reference NEC 230.82, 230.70).
- Rapid shutdown device location/method and relevant labeling.

- c) (For Roof Mounted Systems) A roof plan showing roof layout, solar PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, code exemptions, solar PV system fire classification, and the locations of all required labels and markings.
- d) Provide construction drawings with the following information:
- The type of roof covering and the number of roof coverings installed.
  - Type of roof framing, size of members, and spacing.
  - Weight of panels, support locations, and method of attachment.
  - Framing plan and details for any work necessary to strengthen the existing roof structure.
  - Site-specific structural calculations.
- e) Where an approved racking system is used, provide documentation showing manufacturer of the racking system, maximum allowable weight the system can support, attachment method to roof or ground, and product evaluation information or structural design for the rack.

### PLAN REVIEW

Permit applications can be submitted to **The Town of Guilderland Building Department** in person at **5209 Western Turnpike, Altamont NY 12009.**

### FEES

Existing one- and two-family dwellings:

|                                                              |                 |
|--------------------------------------------------------------|-----------------|
| Structural alterations less than \$1,000                     | \$42            |
| Structural alterations over \$1,000, but less than \$15,000  | \$5 per \$1,000 |
| Structural alterations over \$15,000, but less than \$50,000 | \$4 per \$1,000 |
| Structural alterations exceeding \$50,000                    | \$3 per \$1,000 |

Nonresidential, business use:

|                                                         |                          |
|---------------------------------------------------------|--------------------------|
| First 10,000 cubic feet                                 | \$300                    |
| Over 10,000 cubic feet, but less than 40,000 cubic feet | \$8 per 1,000 cubic feet |
| Over 40,000 cubic feet                                  | \$6 per 1,000 cubic feet |

### INSPECTIONS

Once all permits to construct the solar PV installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar PV system. On-site inspections can be scheduled by contacting **The Guilderland Building Department** by telephone at **518-356-1980.** Inspection requests received within business hours are typically scheduled for the next business day. If next business day is not available, inspection should happen within a five-day window. **THIRD PARTY INSPECTIONS of electrical work are required by a qualified agency.**

In order to receive final approval, the following inspections are required:

**ROUGH FRAMING INSPECTION, IF REQUIRED** During a rough framing inspection, the applicant must demonstrate that the work in progress complies with relevant codes and standards. The purpose of the rough inspection is to allow the inspector to view aspects of the system that may be concealed once the system is complete, such as:

- Framing modifications required to accommodate the new equipment.

It is the responsibility of the applicant to notify **The Guilderland Building Department** before the components are concealed and to provide safe access (including necessary climbing equipment) to the inspector. The inspector will attempt, if possible, to accommodate requests for rough inspections in a timely manner.

**[FINAL INSPECTION]** The applicant must contact **The Guilderland Building Department** when ready for a final inspection. During this inspection, the inspector will review the complete installation to ensure compliance with codes and standards, as well as confirming that the installation matches the records included with the permit application. The applicant must have ready, at the time of inspection, the following materials and make them available to the inspector:

- Proof of a completed electrical inspection by a qualified Third Party Agency.
- Copies of as-built drawings and equipment specifications, if different than the materials provided with the application.

The Town of Guilderland has adopted a standardized inspection checklist, which can be found in the Understanding Solar PV Permitting and Inspecting in New York State document, found here: [www.townofguilderland.org](http://www.townofguilderland.org).

The inspection checklist provides an overview of common points of inspection that the applicant should be prepared to show compliance. If not available, common checks include the following:

- Number of solar PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array components are installed in a neat and workman-like manner.
- Array is fastened and sealed according to attachment detail.
- Appropriate signs are properly constructed, installed and displayed, including the following:
  - Sign identifying PV power source system attributes at DC disconnect.
  - Sign identifying AC point of connection.
  - Rapid shutdown device meets applicable requirements of NEC 690.12.
- Equipment ratings are consistent with application and installed signs on the installation.

## UNIFIED SOLAR PERMITTING RESOURCES

The jurisdiction has adopted the following documents from the New York Unified Solar Permit process:

- Standard Application [www.townofguilderland.org](http://www.townofguilderland.org)
- Understanding Solar PV Permitting and Inspecting in New York State document, which includes sample construction documents, inspection checklist, design review checklist, and labelling guide [www.townofguilderland.org](http://www.townofguilderland.org)

## DEPARTMENTAL CONTACT INFORMATION

For additional information regarding this permit process, please consult our departmental website at [www.townofguilderland.org](http://www.townofguilderland.org) or contact The Guilderland Building Department at 518-356-1980.