



United States Environmental Protection Agency

Solar Photovoltaic Screening Study of Properly Closed Municipal Solid Waste Landfills - Siting Solar Photovoltaics at the Town of Guilderland Landfill, New York

Prepared by the Environmental Protection Agency, Region 2

August 2018

NOTICE:

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of the authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Acknowledgments:

We would like to thank Peter Barber, Town Supervisor, for his assistance with facilitating the Town of Guilderland landfill visit. For questions about the Town of Guilderland and its municipal landfill, he can be contacted at barberp@togny.org.

This report is to be used for screening purposes only.

Additional evaluations will need to be conducted to fully characterize the feasibility and economics of the Town of Guilderland landfill for photovoltaic (PV) installation. Third party solar developers and local utility companies may have technical and financial interests in pursuing potential solar renewable energy projects and should perform additional solar assessments to determine if projects are economically viable.

While the Town of Guilderland landfill has been screened for solar PV, the findings of this solar screening study should not be the sole basis for determining if a PV system at the site is viable. The results of this study are presented in an unbiased manner.

This study does not assess the environmental conditions at the site.

EPA Region 2 Solar Team members:

Fernando Rosado

rosado.fernando@epa.gov

Vince Pitruzzello

vince.pitruzzello@epa.gov

EPA Student Intern:

Jillian Panagakos – Macaulay Honors College

Jillian.panagakos@macaulay.cuny.edu

Technical Support: Department of Energy/National Renewable Energy Lab (DOE-NREL)

Table of Contents

	Pages
I. Purpose of the Solar Screening Report	3
II. Background	3
III. PV System Overview	4
IV. Solar PV System Siting Considerations/Assessment	5
V. PVWatts System Sizing and Performance Results	8
VI. Forecasted Economics	10
VII. Benefits	11
VIII. Re-Powering America's Land	13
IX. Conclusions	14
X. Next Steps	15

List of Tables

Table 1. Siting considerations for solar photovoltaics	5
Table 2. Potential off-takers for the Guilderland Landfill	8
Table 3. PVWatts Site Identification Information for the Guilderland Landfill	9
Table 4. PV System Yearly Performance Results for the Guilderland Landfill	9
Table 5. PVWatts Initial Economic Considerations	10
Table 6. Summary of Applicable Incentives	12

Attachments

Attachment #1 – SunEye Solar Measurements	17
Attachment #2 – Monthly Performance Results for the Guilderland Landfill	18
Attachment #3 – PV Systems Overview	19
Attachment #4 – Glossary or Definition of Terms	22

I. Purpose of the Solar Screening Report

Through the U.S. EPA RE-Powering America's Land Initiative, EPA promotes the reuse of potentially contaminated properties, landfills, and mining sites for renewable energy generation. This initiative identifies the renewable energy potential of these sites and provides useful resources for communities, developers, industry, state and local governments or anyone interested in reusing these sites for renewable energy development. A list of RE-Powering America Initiative resources is provided at the end of this report (Section VIII) and can be found at <http://www.epa.gov/oswercpa>.

This solar screening report provides screening/preliminary information to assist the Town of Guilderland officials in determining the potential for solar photovoltaic (PV) electricity generation at the town landfill. In general, the solar PV system represented in this report is a standalone system sized on proposed available area located at the Town of Guilderland Landfill. It should be noted that the viability of implementing a solar PV system on a landfill is highly impacted by the available area for an array, solar resource, shading, operating status, landfill cap status, distance to transmission lines, distance to major roads, favorable economic conditions, and community support.

II. Background

According to the US Census as of 2010, the town population in Town of Guilderland is approximately 35,303 people. The Town of Guilderland Landfill is operated by town officials and is located off Frenches Mill Road, Guilderland Center, New York and bounded by Frenches Mill Road, Watergate Drive, and Hurst Road (or use Town of Guilderland Transfer Station, 6363 Frenches Mill Rd. P.O. box 154 Guilderland Center, NY 12085). The landfill runs along Frenches Mill Road, and is situated approximately a quarter of a mile north of New York Route 146.

A passive venting system exists on the landfill to manage landfill gas emissions and should be considered before installing solar panels as they may obstruct construction. The New York State Department of Environmental Conservation (NYSDEC) requires quarterly and/or annual monitoring pursuant to approved closure plans and solid waste management facility regulations. For more information about the Town of Guilderland landfill and landfill design, contact Victoria Schmitt, Region 4 - Materials Management Supervisor, Schenectady Regional NYSDEC Office, work phone: (518) 357-2243.

III. Solar PV System Overview

Major System Components - A typical PV system is made up of several key components including:

- PV modules,
- Inverters and
- Balance-of-System components (including mounting racks, hardware for the panels, and wiring for electrical connections). Electrical connections (including wiring, disconnect switches, fuses, and breakers) are required to meet electrical code (e.g., NEC Article 690) for both safety and equipment protection.

In most traditional applications, wiring from the arrays to inverters (typically positioned off the landfill cap) and inverters to point of interconnection is generally run as direct burial through trenches or above ground using water/gas proof electrical conduits. For landfills, a solar PV array is connected to a mounting system that is anchored to a uniformly loaded concrete foundation or a ballasted system (see figure 1). It is recommended that PV system vendors reflect these costs in the requests for proposals when costing out the overall system.

Additional information about solar PV systems can be reviewed in Attachment #3.



Figure 1. Town of Ulster Landfill, NY – Ulster County Executive Michael P. Hein
<https://www.youtube.com/watch?v=likSbeKXrCY>



Figure 2. Fixed Axis Solar PV Array on a ballasted concrete foundation at the Town of Beacon Landfill, NY.

IV. Solar PV Siting Considerations/Assessment

Siting Considerations

On October 31, 2017, the U.S. Environmental Protection Agency, Region 2 (EPA) team, in cooperation with Town of Guilderland officials visited and screened the closed landfill for potential solar photovoltaic (PV) renewable energy generation. In general, for closed landfills, a minimum of 2 usable acres is recommended to site PV systems. Usable acreage is typically characterized as "flat to gently sloping" southern exposures that are free from obstructions and get full sun for at least a 6-hour period each day. Other considerations for siting landfills for solar PV generation include:

Table 1. Siting considerations for solar photovoltaics
Figure 2. Fixed Axis Solar PV Array on a ballasted concrete foundation

Siting Concerns	Looking for
Age of the properly closed/capped landfill	Minor settlement impacts based on the type of waste and age of the landfill. Landfill cap integrity must be maintained during construction and life of the solar PV array.
Site topography	Existing flat area and surface stability for the PV Array. Avoid slope/grade landfill areas > 10 degrees. Slope instability can give way and displace panels & impact solar performance.
Surface and vegetative conditions	Well maintained vegetative cover with minimum soil erosion concerns. Need to have existing storm water controls.
Shading/physical sunlight obstructions on the landfill	Open area with minimum shading from trees and existing on-site buildings in order to maximize sunlight on each solar panel.
Available access roads and close distance to highways/developed roads	Developed roads and easy access for material shipment and to support heavy construction vehicles entering the landfill.
Distance to available electrical transmission lines	Nearby utility lines to interconnect with the proposed solar PV system. Longer distance will have cost and efficiency impacts.
Landfill Gas	Inactive or passive gas wells with proper engineering controls. Integrating solar and landfill gas systems may require the use of gas-proof electrical conduits/fittings.
Nearby natural resources	Nearby wetlands or streams/water bodies. Be aware of any potential flooding concerns and existing endangered species inhabiting the landfill.
Town restrictions	Any specific local codes requirements/restrictions and future land reuse established by the municipality.

During the landfill visit, the EPA solar team screened for available flat and open landfill area, free from sunlight obstruction and suitable to support solar panels. The EPA solar team also used a Solmetric SunEye¹ solar path calculator to assess shading at particular locations by analyzing the sky view where solar panels can be potentially located. By finding the solar access, the instrument can determine if the area is appropriate for solar energy generation.

For information about the Solmetric SunEye and the SunEye annual solar access summary for the Town of Guilderland landfill see Attachment #1.

¹ More information on this tool can be found at: <http://www.solmetric.com/>

Usable Landfill Acreage

Based on Geographic Information System (GIS) and on-site assessment, the total recommended usable landfill area for solar PV generation is approximately 16.7 acres. This proposed usable area corresponds to a relatively flat open portion of the landfill. Figure 3 shows an aerial image of the Town of Guilderland landfill with the recommended usable solar PV areas shaded in light red, blue, yellow, and pink polygons. Although the EPA team recommends an estimated 16.7 acres for the proposed solar PV usable area, this acreage can be reassessed and adjusted by the town or a potential third-party solar developer working with the town.

The yellow sun icons in Figure 3 represent the locations where SunEye data points were taken to measure solar potential. More information about SunEye data can be found in Attachment #1. **Overall, the solar access yields averaged above 96% annual solar exposure for the landfill, which is within the favorable annual solar access range for solar PV systems.** More SunEye data can be found in Attachment #2. The white icons represent the locations of passive gas vents on the landfill, which need to be considered for safe set back distance from the solar panels.




Figure 3. Aerial view of the feasible area for PV on the Town of Guilderland landfill (taken with the GIS Platform)

Landfill observations:

- Overall, the landfill areas are well-suited for solar implementation.
- There is continuous property throughout the entire landfill.
- The southern and western portions of the landfill are shaded by trees at the perimeter.
- The eastern portion of the landfill is bound by fencing.
- In the center of the landfill is an area designated to mulching, waste collection, and parking.
- Electrical distribution transmission lines run along Frenches Mill Road.
- Overall, there is a large central area open to sunlight with minimal shading throughout.

The following photos of the Town of Guilderland landfill were collected during the site visit and illustrate some of the potential usable PV solar areas.



Figure 4A. Looking northeast from the west of Area #1.



Figure 4B. Looking at south from the northeast of Area #1.



Figure 4C. Looking south from the northeast middle of Area #2.



Figure 4D. Looking west from the east of Area #4.



Figure 4E. Looking east from the center of Area #3.



Figure 4F. Looking west from the eastern portion of Area #3.

Figures 4A – 4F - Images of the Town of Guilderland landfill taken by EPA.

Transmission/Utility Resources

Electrical transmission lines run along Frenches Mill Road approximately 0.11 miles east of the landfill. In general, the distance from the proposed solar PV system to the point of interconnection with electrical transmission should be within a half mile distance in order to yield more viable economic conditions.

It is highly recommended that the Town of Guilderland consult with the electric distribution company (EDC) serving the area to discuss the potential for a solar project. In general, a preliminary interconnection transmission study from the local EDC should be performed early in the process if the Guilderland town officials decide to pursue PV solar generation on the landfill. The EDC serving the Town of Guilderland is National Grid². While the interconnection to the local transmission line seems favorable, early coordination with Central Hudson Gas and Electric is required to ensure that installations of distributed generation systems are properly designed to safely operate in parallel to the utility system, and to provide for Value Stack crediting if applicable. In New York State, Value Stack crediting is allowed for non-residential solar PV generation systems less than 2 MWs in size and a bill has been drafted to increase this number to 5 MWs for non-residential solar. For more information about the Value Stack crediting system, go to section VII of the study or visit <https://www.nyseda.ny.gov/All-Programs/Programs/NY-Sun/Contractors/Value-of-Distributed-Energy-Resources>.

The preliminary interconnection study will also help the EDC to determine the feasibility of interconnecting to the electrical grid, assess whether potential electrical upgrades are needed, and estimate the interconnection costs. The EDC will also evaluate the available capacity of the transmission line to accommodate the solar power generated from the landfill. All technical pertinent information about the proposed solar PV system should be provided to the EDC in accordance with the application requirements.

Potential Off-Takers of the Generated Solar PV

As part of the PV siting consideration, potential solar PV off-takers were also identified. According to town officials, there are several local facilities that could be potential off-takers of the electricity generated by solar PV system on the landfill. Some of the potential off-takers identified include:

Table 2. Potential off-takers for the Guilderland Landfill

Potential Off-takers
Northeast Industrial Park
Town of Guilderland Highway Department and Transfer Station
Guilderland Town Animal Shelter

V. PVWatts System Sizing and Performance Results

PVWatts Analysis

PVWatts³ calculator is an online tool developed by the Department of Energy - National Renewable Energy Laboratory (DOE-NREL) to estimate the electricity production of a grid-connected ground or roof-mounted photovoltaic system. It requires only a few inputs including the location of the system, system size, and basic design parameters such as whether the system will be a fixed tilt or a single-axis tracking. The design parameters have default values or users can adjust them according to their needs.

² National Grid https://www9.nationalgridus.com/masselectric/business/energyeff/distributed_generation.asp

³ <http://www.nrel.gov/rredc/pvwatts/> PVWatts®

The DC system size required in PVWatts is determined with an acre-to-power conversion factor. Based on research done by NREL for ground mounted solar PV systems and other similar solar PV on landfills, a value of 5.74 acres/MW has been used for a fixed-tilt system. However, based on recent discussions with solar developers involved with solar projects on landfills and improvements with solar technology and efficiency, a conversion value of 4 acres/MW was assumed for this study. For the Town of Guilderland landfill, this study recommends 16.7 acres of the usable landfill area for a system size of 4.17 MW DC.

The landfill location is used to connect to NREL’s Typical Meteorological Year (TMY) data which is the closest weather data source. NREL has compiled TMY data for thousands of locations throughout the United States. This data includes the solar irradiance, which is a measurement of solar radiation on the surface of the earth and is measured by the power (Watts) per unit area (m²), W/m². The solar radiation values represent the resource available to a flat plate collector, such as a photovoltaic panel, oriented due south at an angle from horizontal to equal to the latitude of the collector location. Solar radiation, or insolation (irradiance multiplied by time), is measured in units of Watt hours per unit area during a specific time interval. Solar radiation above 3.5 kWh/m²/day, is considered favorable when considering PV siting locations.

For the Town of Guilderland landfill, the TMY data is taken from Albany County, Airport (AP), New York (8.25 miles from the landfill location) and the solar radiation level was measured at **4.52 kWh/m²/day**. The weather station identification information, PV system specifications, energy specifications, and performance results for the Town of Guilderland landfill are provided in Table 3 and Table 4.

The monthly performance results for the proposed solar PV systems at the Town of Guilderland Landfill as calculated by PVWatts can be found in Attachment #2.

Table 3. PVWatts Site Identification Information for the Guilderland Landfill

Weather and PV System Technical Specifications	
Weather Data Source:	Albany County AP, New York
Latitude/Longitude:	42.75° N, -73.80° W
Array Type:	Fixed-Tilt
Solar Radiation Levels:	4.52 kWh/m ² /day
System Losses*:	14%
Array Tilt, Array Azimuth:	20°, 180° South

*Systems Losses is another input parameter for the PV Watts calculator. It is also referred to as the DC to AC Derate Factor and is calculated from all of the losses that the system experiences when converting DC power to grid-ready AC power. These include accuracy for PV module nameplate DC rating, conversion efficiency of the inverter and transformer, mismatch, diodes and connections (voltage drops), DC and AC wiring (resistive losses), soiling, system availability, shading, sun-tracking and age.

Table 4. PV System Yearly Performance Results for the Town of Guilderland Landfill

Usable LF Area for Solar PV	Fixed-Tilt PV System			
	DC System Size*	AC Energy Based on PVWATTS	GHG Reduction** (metric tons CO _{2e})	GHG Emissions Equivalent to # of Vehicles Driven Yearly**
16.7 acres	4.17 MW DC	5,242,905 kWh/yr	3,902 MTCO_{2e}	836 Cars

*Assumes an area-to-power conversion of 4 Acres/MW based on historical data provided by NREL and other similar solar on landfill projects.

** EPA’s Greenhouse Gas (GHG) Equivalencies Calculator (<http://www2.epa.gov/energy/greenhouse-gas-equivalencies-calculator>) was used to determine the GHG reductions based on the proposed AC energy.

Cautions for Interpreting Results – Weather Variability

Monthly and yearly energy production is modeled using photovoltaic system selected parameters and weather data that is typical or representative of long-term averages. Because weather patterns vary from year to year, the values in Table 4 are better indicators of long-term performance than of performance for a specific month or year. Photovoltaic system performance is largely proportional to the amount of solar radiation received, which may vary from the long-term average by ±30% for monthly values and ±10% for annual values.

VI. Forecasted Economics

In general, the forecasted economics for the solar PV system should factor the PV arrays/tilt and orientation and balance of system (BOS) components including the inverter and electrical supply/equipment costs, as well as the installation cost. Other cost factors for a PV system will depend on the system size, geographic location, mounting structure, type of PV module, and other soft costs (permit fees, installation/interconnection labor costs, sales tax, installer/developer profit, customer acquisitions costs, and transaction costs). For more information about understanding and managing solar soft costs go to <http://energy.gov/eere/sunshot/soft-costs>.

Based on NREL's Solar PV Price and Cost Breakdown Study⁴, significant cost reductions in 2016 shows the average cost for commercial and utility-scale ground-mounted systems (includes the engineering, procurement, and construction (EPC) system hardware, other EPC direct/indirect costs, and developer costs) for different installed capacities. The actual cost declined from \$3.76/W in the fourth quarter of 2010 to \$1.42/W in the first quarter of 2016. However, this price is for systems 100 MW in size, much larger than the system that is being proposed for the Town of Guilderland landfill. An interpolation was made using data from the NREL Prices and Cost Breakdown to estimate cost for a system of 2.475 MW DC. As a result, an installed capacity of 4.17 MW gives a cost of \$2.03/W. However, for a landfill site it is necessary to use a ballasted system in order to ensure the integrity of the landfill cap. This increases the cost by approximately 25%, bringing it to \$2.55/W, which is the value used for this analysis.

With an increasing demand and supply, potential cost reductions may be expected as market conditions continue to evolve. It should be emphasized that this is a very rudimentary estimation of the economics involved for this proposed area and a more detailed analysis will be necessary moving forward.

The projected cost only factors an initial installation costs and does not reflect the true cost of the system since available NYS incentives that may lower the costs are not included and the associated soft costs to develop the solar PV will vary for this project. Additional steps may be necessary in order to install PV panels at these sites, such as site preparation and the interconnection requirements, which can drive the overall cost. Table 5 provides the initial system costs for a fixed tilt PV system based on the above stated pricing assumptions. The project is expected to have an optimal 25-year lifespan, although the system can be reasonably expected to continue operation past this point.

Table 5. PVWatts Initial Economic Considerations

Fixed-Tilt PV System	
Initial installation system cost	\$2.55 /W DC
Town of Guilderland Landfill PV System Size (16.7 acres) *	4.17 MW DC
Projected Estimated System Cost (without financial incentives)	\$10,639,875

*Assumes an area-to-power conversion of 4 Acres/MW.

⁴ <http://www.nrel.gov/docs/fy16osti/67142.pdf> U.S. Photovoltaic Prices and Cost Breakdowns: Q1 2016 Benchmarks for Residential, Commercial, and Utility Scale Systems

VII. Benefits

In general, due to the presence of suspected or known contaminants, landfills have limited redevelopment potential and solar PV installations can be a viable reuse. Many municipal solid waste (MSW) landfills are particularly well-suited for solar development because they are often:

- Located near critical infrastructure including electric transmission lines and roads;
- Located near areas with high energy demand (e.g., large population bases);
- Constructed in areas of low grade (0-10%) needed for siting of solar PV structures;
- Offered at lower land costs when compared to open space;
- May be adequately zoned for renewable energy;
- May have environmental conditions that are not well-suited for commercial or residential redevelopment;
- Are able to accommodate Value Stacked or utility scale projects; and

Other benefits with solar on landfills:

- Can provide short and long term job opportunities;
- May reduce the environmental impacts of energy systems (e.g., reduce greenhouse gas emissions).

The **New York State Energy Research and Development Authority (NYSERDA)** promotes energy efficiency and the use of renewable energy sources in New York. According to NYSERDA, solar PV generation offers the following key benefits:

- PV systems are gentle on the environment, in contrast with electricity generated by fossil fuels;
- PV-generated electricity creates no noise, air, or water pollution;
- PV systems provide long-term stabilization of electrical costs;
- When combined with a battery backup system, a PV unit can provide power when utility power is not available.

In addition, this study outlines various financial incentives (Section VI – Incentives) that could assist in financing the implementation of a solar PV system including incentives offered by NYSERDA.⁵ To learn about programs and funding opportunities available through NYSERDA from the NY-Sun Initiative, go to <http://www.ny-sun.ny.gov/> or <https://www.nyserda.ny.gov/All-Programs/Programs/NY-Sun/Megawatt-Block-Dashboards>.

Value Stack Crediting:

In New York State, another benefit to implementing a renewable energy system is **Value Stack crediting**. This system of reimbursement for electricity generation is allowed for non-residential solar PV generation systems less than 2 MWs in size. Although current New York State Laws limit non-residential solar producers to 2 MWs, a bill has been proposed to increase this number to 5 MWs. More information about the bill's status can be found at: www.nysenate.gov/legislation/bills/2017/s8273. In a conventional Value Stack situation, a **customer-sited renewable energy system** is connected to the utility grid through a customer's utility meter. This is known as "behind-the-meter generation." At any given moment, if the site is using more electricity than the system is producing, all the electricity produced by the system is used on-site and the site's electricity needs are supplemented from the grid. If the site is using less electricity than the system is producing, the excess electricity is exported to the grid and the customer receives a monetary credit based on the time and location of energy generation. This is typically recorded as negative use and is commonly referred to as the "meter spinning backwards." At the end of the billing cycle, the grid-supplied electricity and the credits for any exported electricity are reconciled, and any surplus credits can be carried forward to the next billing cycle. The specifics of Value Stack crediting are dependent on the customer's service classification. Additional information about Value Stack crediting can be found at: <https://www.nyserda.ny.gov/All-Programs/Programs/NY-Sun/Contractors/Value-of-Distributed-Energy-Resources>. It is highly recommended that Ulster County consults with Central Hudson Gas and Electric to discuss Value Stack crediting opportunities.

⁵ <http://www.nyserda.ny.gov/>

Power Purchase Agreements:

A number of municipalities that own or operate landfills have expressed interest in potential revenue flow from solar PV systems. In some cases, revenue can be generated by the use of PV on a landfill site pending actual site conditions, financial incentives, economic conditions, and support from the utility companies. While the findings of this report do not recommend how a solar array at a landfill will be financed, if the municipality decides that they do not want to invest their own funds to build the solar site, they can consider entering into a Power Purchase Agreement (PPA) with a solar developer who would assume the cost of development. To learn more about PPA structures, please go to the following PPA checklist for state and local governments link: <http://www.nrel.gov/docs/fy10osti/46668.pdf> or the Interstate Renewable Energy Council PPA toolkit for local governments: <http://www.irecusa.org/solar-power-purchase-agreements-a-toolkit-for-local-governments/>

Incentives:

The economics of a PV system will also depend on NYS financial incentives, available federal tax credit, the regional cost of electricity, the solar resource, solar panel tilt and orientation, site conditions, distance to the electrical interconnection, and other critical requirements highlighted in this report. Table 6 provides several possible financial incentives that can be considered by the Town of Guilderland officials to assist with financing the proposed solar PV systems.

Table 6. Summary of Applicable Incentives

Federal and State Solar Investment Tax Credit	As of December 2015, system owners may continue to qualify up to 30% Federal Investment Tax Credit which is expected to step down to 26 percent in 2020 and 22 percent in 2021. After 2023, the residential credit will drop to zero while the commercial and utility credit will drop to a permanent 10 percent. Always consult with your qualified tax professional or accountant to determine your eligibility for tax credits.
Modified Accelerated Cost Recovery System (MACRS)	MACRS depreciation is also considered another important financial incentive. The MACRS is a method of depreciation in which a business' investments in certain tangible property are recovered, for tax purposes, over a specified time period through annual deductions. Qualifying solar energy equipment is eligible for a cost recovery period of five years. More information about MARCS is available at: http://www.seia.org/policy/finance-tax/depreciation-solar-energy-property-macrs .
NY-Sun Commercial/Industrial Incentive Program (PON 3082)	For installations of Solar PV Systems greater than 200 kW, incentives are available on a rolling application first-come, first-served basis for eligible projects. More information is available at: http://www.nyserda.ny.gov/Funding-Opportunities/Current-Funding-Opportunities/PON-3082-NY-Sun-Commercial-Industrial-Incentive-Program .
NY-Sun Megawatt Block Program	In June 2018, NYSERDA's NY-Sun Megawatt Block program was redesigned to include larger solar projects and encourage development on landfills and brownfield sites. More information is available at: https://www.nyserda.ny.gov/About/Newsroom/2018-Announcements/2018-06-18-NYSERDA-Announces-Redesign-of-NY-Suns-Megawatt-Block-Program .
Clean Energy Financing Arrangements	The New York Green Bank invites private sector capital providers and other clean energy industry participants to propose partnership arrangements with the Green Bank that would facilitate the financing of clean energy projects (including energy generation and energy savings projects) in the State of New York. More information is available at: http://www.nyserda.ny.gov/Funding-Opportunities/Current-Funding-Opportunities/RFP-1-Clean-Energy-Financing-Arrangements
Other Incentives	For other applicable incentives, go to the following website: http://programs.dsireusa.org/system/program?fromSir=0&state=NY

VIII. RE-Powering America's Land

Through the RE-Powering America's Land Initiative, the U.S. EPA promotes the reuse of potentially contaminated properties, landfills, and mining sites for renewable energy generation. This initiative identifies the renewable energy potential of these sites and provides useful resources for anyone interested in reusing these sites for renewable energy development. Various RE-Powering America Initiative resources are summarized below and can be found at <http://www.epa.gov/oswercpa>.

- **Mapping and Screening Tools** - Under Mapping and Screening tools, EPA's RE-Powering America's Land team screened more than 80,000 potentially contaminated sites and MSW landfills, assessing the suitability of nearly 43 million acres across the country for site renewable energy generation facilities, including utility-scale solar. Maps depicting the details of these EPA tracked sites can be found at <https://www.epa.gov/re-powering/re-powering-mapping-and-screening-tools>. These maps enable users to view screening results for various renewable energy technologies at each site.
- **Technical Assistance and Support** - As part of the RE-Powering America's Land Initiative, the EPA and the U.S. Department of Energy's National Renewable Energy Laboratory (NREL) have evaluated the feasibility of developing renewable energy production on Superfund, brownfields, and former landfills or mining sites. This project paired EPA's expertise on contaminated sites with the renewable energy expertise of NREL. A list of feasibility studies for renewable energy production using various technologies, including solar, and can be found at <https://www.epa.gov/re-powering/re-powering-feasibility-studies>.
- **Redevelopment Tools and Resources** – Under Redevelopment Tools and Resources, EPA and NREL created the joint publication, “**Best Practices for Siting Solar PV on Municipal Solid Waste Landfills**” - <https://www.epa.gov/re-powering/best-practices-siting-solar-photovoltaics-municipal-solid-waste-landfills> to provide assistance in addressing common technical challenges of siting PV on MSW landfills (such as impacts to landfill settlement differentials and the PV solar performance, impacts to other landfill systems, understanding landfill cap integrity/characteristics, and understanding landfill post-closure requirements for solar PV design considerations) and provide other useful information for solar developers, landfill owners, and federal, state, and local government entities. Another document for stakeholder consideration is the “**RE-Powering Finance Fact Sheet**” – <https://www.epa.gov/re-powering/financing-renewable-energy-projects-contaminated-lands-landfills-and-mine-sites> and “**Revised Bona Fide Prospective Purchaser (BFPP) Provisions Enforcement Guidance for Tenants**” - <https://www.epa.gov/enforcement/guidance-treatment-tenants-under-cerclas-bona-fide-prospective-purchaser-bfpp-provision>.
- **Fact Sheets and Success Stories** - The RE-Powering team highlights numerous successful of renewable energy projects throughout the United States. The RE-Powering America team also maintains a list of completed renewable energy installations on contaminated sites and landfills. To date, the RE-Powering Initiative has identified 274 renewable energy installations on 261 sites, with a cumulative installed capacity over 1,450 megawatts (MW) and consistent growth in installations since the inception of the RE-Powering Initiative. For information, go to <https://www.epa.gov/re-powering/re-powering-tracking-matrix>.

IX. Conclusions

Overall, the Town of Guilderland Landfill appears to have favorable site conditions to support solar PV generation and economic viable use. The landfill offered relatively flat open vegetative area with minimal shading concerns (the southern and western portions of the landfill are shaded by trees at the perimeter) and high solar access making it an ideal site to install solar panels. The landfill slopes towards the south and the recommended usable solar PV areas proposed locations is depicted in Figure 3. The solar PV system size and performance for the landfill is based on the recommended usable areas (illustrated in Table 4). In general, the proposed usable area for solar PV amounted to 16.7 acres with an installed capacity of 4.17 MW DC. Electrical transmission lines are conveniently located near the landfill, however early coordination National Grid for interconnection studies will be required if town officials decide to move forward with a solar PV project.


While this solar screening study recommended a PV system size based on proposed usable areas, the actual system installation will need to factor the availability of funds, the amount of solar power needed, and amount of solar power that can be sold. As indicated earlier, a third-party developer power purchase agreement (PPA) is another feasible way for a system to be financed for this site. In exchange for access to a site through a lease arrangement, third-party solar developers can finance, develop, and operate the solar projects utilizing their own expertise and sources of financing. These private enterprises are also able to take advantage of the federal tax benefits that cannot be captured by municipalities (or other entities that do not pay corporate income taxes), which should lower the total system cost. If the town officials decide to proceed with a solar system installation and work with a third-party solar developer, the developer can sell the electricity to the site host (pending on the potential cost savings for local town facilities between current utility rates and the solar utility rate) or to the local utility via a PPA - which will sell the electricity at negotiated rate for a fixed period of time for a term typically varying from 20-25 years. Thus, economic benefits from solar generation on the landfill could include competitively priced electricity from the project, revenues via land lease payments from a solar developer, potentially reduced landfill maintenance costs, job creation, and stimulation of the local economy during solar construction.

By using obtainable and accessible land that is unavailable for redevelopment allows for repurpose of land that would not otherwise be productive and reduces greenhouse gas emission from current power sources. In case town officials are interested in pursuing solar PV generation, additional options could be explored to make the solar PV generation more viable while understanding the economic impacts and maintaining the integrity of the landfill cap design. The Town of Guilderland officials should also coordinate early with representatives from the New York State Department of Environmental Conservation and share the proposed solar plans on the closed landfill. Furthermore, town officials or a potential third-party solar developer could reassess and expand the usable solar PV landfill area proposed in this screening study. Based on EPA's screening and assessment of the existing physical landfill conditions, EPA supports the potential of solar PV generation at the Town of Guilderland landfill.

X. Next Steps

Early and proper planning with other key stakeholders is critical to the success of a solar PV system. The following stakeholders should be consulted in the early stages of a solar PV project:

New York State Department of Environmental Conservation (NYSDEC):




The Town of Guilderland must coordinate early with the **NYSDEC**. To initiate this process, contact For more information about the landfill cover, landfill design, and NYSDEC annual landfill monitoring, please contact James Lansing, Region 3 Materials Management Engineer at (845) 256-3123 or via email at james.lansing@dec.ny.gov. NYSDEC's review and approval of the proposed solar PV work is necessary in order to ensure that the integrity and protective measures put in place for the existing landfill cap are maintained throughout the life of the project. To that end, it will be necessary to provide all related information to NYSDEC for the proposed solar PV system including:

- Location of the landfill and the PV system size,
- Estimated usable area on the landfill for the solar PV installation,
- The mounting foundation type placed on the landfill,
- The landfill cap's ability to withstand both the construction and long-term operation loads of the PV system,
- Impacts to the landfill cap integrity,
- Proper set back from the gas vents and no impacts to the gas venting,
- Potential storm water management issues, and
- Any additional information requested by NYSDEC.


In general, NYSDEC regional representatives' names and contact information can be found at <http://www.dec.ny.gov/chemical/76718.html>. For general questions involving solar PV redevelopment on New York landfills, contact Susan Momberger, P.E., Division of Materials Management at (518) 402-8675 or via email at susan.lasdin-momberger@dec.ny.gov

Coordination with the Local Utility Provider:



National Grid should be consulted early in the planning stages so that the municipality can be alerted to any potential transmission interconnection issues that might exist or equipment upgrades needed to facilitate the solar project. The Town of Guilderland officials may request a transmission interconnection study from. As indicated earlier, all technical pertinent information about the proposed solar PV system should be provided to National Grid in accordance with their application requirements.


Coordination with the NYSERDA, NY SUN:



In addition to the solar PV financial incentives from NYSERDA, the NY-Sun program offers additional resources to municipalities interested in developing solar in their community. Of particular interest, is the "Solar Guideline for Local Governments": <https://www.nyserda.ny.gov/All-Programs/Programs/NY-Sun/Communities/Local-Government-Training-and-Resources/Solar-Guidebook-for-Local-Governments>. Municipalities can also obtain technical assistance and learn more about the solar procurement process by visiting <https://training.ny-sun.ny.gov/resources-5>.

For more information and training offered under the NY-Sun program or any assistance needed with electrical interconnection, contact Houtan Moaveni at (518) 862-1090, ext. 3016, or Houtan.Moaveni@nyserda.ny.gov.

Coordination with the New York Power Authority (NYPA):



The New York Power Authority (NYPA) is authorized, through New York Public Authorities Law 1005(17), to provide strategic, technical, and other assistance to its customers to support implementation of energy related projects including renewable energy initiatives. NYPA is uniquely positioned to procure vendors on behalf of its customers.

NYPA is committed to working with public entities to incorporate solar energy at their facilities by providing customized solar services. Through these services, NYPA acts as a trusted energy advisor to its customers, and is well positioned to oversee both policy and technical aspects of their projects. NYPA can engage at any and all phases of a project from inception to operation of the system, including financial analysis, feasibility assessment and site design, development and solicitation of a request for proposals (RFP), and contract mechanism recommendation.

NYPA is in development of over 60 MW of distributed solar PV for customers ranging from the Cities, Counties and Town's to K-12 schools, State Universities and State Agencies. By 2020, NYPA aims to develop at least 125 MW of renewable energy for the state of New York located at public facilities.

For more about the services offered by the New York Power Authority and their associated costs, go to www.nypa.gov or contact Christina Iwaniw, Certified Energy Manager, at Christina.iwaniw@nypa.gov or call (914) 390-8031.

As a reminder, this report is to be used for screening purposes only.

Additional evaluations will need to be conducted to fully characterize the feasibility and economics of the Town of Guilderland landfill for PV installation. Third party solar developers and local utility companies may have technical and financial interests in pursuing potential solar renewable energy projects and should perform additional solar assessments to determine if projects are economically viable.

This study does not assess the environmental conditions at the site.

Attachment #1 – SunEye Solar Measurements

The EPA solar assessment team used a Solmetric SunEye⁶ solar path calculator to assess shading at particular locations by analyzing the sky view where solar panels will be located. By finding the solar access, the instrument can determine if the area is appropriate for solar panels. PV modules are very sensitive to shading. When shaded (either partially or fully), the panel is unable to optimally collect the high-energy beam radiation from the sun. PV modules are made up of many individual cells that all produce a small amount of current and voltage. These individual cells are connected in series to produce a larger current. If an individual cell is shaded, it acts as resistance to the whole series circuit, impeding current flow and dissipating power rather than producing it. By finding the solar access, it can be determined if the area is appropriate for solar power generation.


The assessment team collected nine Solmetric SunEye data points (skyline views) at across the entire perimeter of the landfill in sections with adequate flat area as shown is Figure 3. Overall, **solar access yields averaged 96%** annual solar exposure, which is within the favorable annual solar access range for PV systems.

Session Properties

Name	Guilderland Landfill
Creation Date	10/31/2017 8:35
Note	(none)
Location	42.7°N, 74.0°W Mag Dec: 13.4°W Time Zone: GMT-05:00

Solar access averages of 9 skylines in this session

Skylines Averaged: Sky01, Sky02, Sky03, Sky04, Sky05, Sky06, Sky07, Sky08, Sky09



TSRF averages of 9 skylines in this session: 96%

Figure 5. Session properties for Solmetric SunEye

The Total Solar Resource Fraction (TSRF) is the ratio of insolation available accounting for both shading and Tilt and Orientation Factor (TOF), compared to the total insolation available at a given location at the optimum tilt and orientation and with no shading. TRSF is also expressed in percent. The TOF is the solar insolation at the actual tilt and orientation divided by the insolation at the optimum tilt and orientation, expressed in percent.

⁶ More information on this tool can be found at: <http://www.solmetric.com/>

Attachment #2 – Monthly Performance Results for the Town of Guilderland Landfill

Performance Results 4,170 kW Fixed-Tilt PV System		
Month	Solar Radiation* (kWh/m²/day)	AC Energy (kWh)
January	2.79	304,034
February	3.69	359,423
March	4.74	488,583
April	5.33	511,025
May	5.80	563,296
June	6.36	577,450
July	6.09	566,125
August	5.66	528,547
September	5.13	468,111
October	3.53	349,567
November	2.81	279,636
December	2.29	247,110
Total	4.52* Monthly Average	5,242,905 **

**Solar Radiation values above 3.5 kWh/m²/day are considered favorable when considering PV siting locations.*

***The solar photovoltaic performance degradation, a reduction in power generation due to long-term exposure, is under 1 % per year. Silicon modules have a lifespan range of 25–30 years but can keep producing energy beyond this range. For information about, a reduction in power generation due to long-term exposure, go to <http://www.nrel.gov/docs/fy12osti/51664.pdf>*

Attachment #3 – PV Systems Overview

Major System Components

A typical PV system is made up of several key components including:

- PV modules,
- inverters and
- balance-of-system components (including mounting racks, hardware for the panels, and wiring for electrical connections). Electrical connections (including wiring, disconnect switches, fuses, and breakers) are required to meet electrical code (e.g., NEC Article 690) for both safety and equipment protection.

In most traditional applications, wiring from the arrays to inverters and inverters to point of interconnection is generally run as direct burial through trenches. It is recommended that PV system vendors reflect these costs in the requests for proposals when costing out the overall system.



Figure 6. Ground mount array (source: NREL)

Solar PV cells are the electricity-generating component of a solar energy system. When sunlight (photons) strikes a PV cell, an electric current is produced by stimulating electrons (negative charges) in a layer in the cell designed to give up electrons easily. The existing electric field in the solar cell pulls these electrons to another layer. By connecting the cell to an external load, this current (movement of charges) can then be used to power the load, e.g., light bulb.




Figure 7. Generation of electricity from a PV cell (source: EPA)

PV cells are assembled into a PV panel or module. PV modules are then connected to create an array. The modules are connected in series and then in parallel as needed to reach the specific voltage and current requirements for the array. The direct current (DC) electricity generated by the array is then converted by an inverter to usable alternating current (AC) that can be consumed by adjoining buildings and facilities or exported to the electricity grid. PV system size varies from small residential (2-10 kilowatts (kW)), commercial (100-500 kW), to large utility scale (10+ megawatts (MW)). Central distribution plants are also currently being built in the 100 MW+ scale. Electricity from utility-scale systems is commonly sold back to the electricity grid.

The solar array has to be secured and oriented optimally to maximize system output. The structure holding the modules is referred to as the mounting system. The mounting systems can be ground mounted utilizing a ballast system on top of a landfill cap where there are commonly large unshaded areas. For ground mount systems, the mounting system can be either directly anchored into the ground (via driven piers or concrete footers) or ballasted on the surface without ground penetration. Mounting systems must withstand local wind loads, which range from 90–120 mph range for most areas or 130 mph or more for areas with hurricane potential. Depending on the region, snow and ice loads must also be a design consideration for the mounting system.

PV Module

Module technologies are differentiated by the type of PV material used, resulting in a range of conversion efficiencies from light energy to electrical energy. The module efficiency is a measure of the percentage of solar energy converted into electricity. Two common PV technologies that have been widely used for commercial- and utility-scale projects are crystalline silicon and thin film.

Crystalline Silicon

Traditional solar cells are made from silicon. Silicon is quite abundant and nontoxic. It builds on a strong industry on both supply (silicon industry) and product side. This technology has been demonstrated for a consistent and high efficiency over 30 years in the field. The performance degradation, a reduction in power generation due to long-term exposure, is under 1% per year. Silicon modules have a lifespan in the 25-30-year range but can keep producing energy beyond this range.

Typical overall efficiency of silicon solar panels is between 12% and 18%. However, some manufacturers of mono-crystalline panels claim an overall efficiency nearing 20%. This range of efficiencies represents significant variation among the crystalline silicon technologies available. The technology is generally divided into mono- and multi-crystalline technologies, which indicates the presence of grain-boundaries (i.e., multiple crystals) in the cell materials and is controlled by raw material selection and manufacturing technique. Crystalline silicon panels are widely used based on deployments worldwide.

Figure 8 shows two examples of crystalline solar panels: mono- and multi-silicon installed on tracking mounting systems.



Figure 8. Mono- and multi-crystalline solar panels. Photos by (left) SunPower Corporation, NREL 23816 and (right) SunPower, NREL 13823

Thin Film

Thin-film PV cells are made from amorphous silicon (a-Si) or non-silicon materials such as cadmium telluride (CdTe). Thin-film cells use layers of semiconductor materials only a few micrometers thick. Due to the unique nature of thin films, some thin-film cells are constructed into flexible modules, enabling such applications as solar energy covers for landfills such as a geomembrane system. Other thin film modules are assembled into rigid constructions that can be used in fixed tilt or, in some cases, tracking system configurations.

The efficiency of thin-film solar cells is generally lower than for crystalline cells. Current overall efficiency of a thin-film panel is between 6% and 8% for a-Si and 11-12% for CdTe. Industry standard warranties of both crystalline and thin film PV panels typically guarantee system performance of 80% of the rated power output for 25 years. After 25 years, they will continue producing electricity at a lower performance level.

Mounting Systems

The array has to be secured and oriented optimally to maximize system output. The structure holding the modules is referred to as the mounting system. Typical ground mounted systems can be categorized as fixed-tilt or tracking. Fixed-tilt mounting structures consist of panels installed at a set angle, typically based on site latitude and wind conditions, to increase exposure to solar radiation throughout the year. Fixed-tilt systems are used at many landfill sites. Fixed-tilt systems have lower maintenance costs but generate less energy (kWh) per unit power (kW) of capacity than tracking systems. The selection of mounting type is dependent on many factors including installation size, electricity rates, government incentives, land constraints, soil conditions, alignment and latitude requirements, and local weather.

The mounting system design will also need to meet applicable local building code requirements with respect to snow, wind, and seismic zones. Selection of mounting types should also consider frost protection needs especially in cold regions. Contaminated land applications may raise additional design considerations due to site conditions, including differential settlement. Selection of the mounting system is also heavily dependent on anchoring or foundation selection.

Inverters

Inverters convert DC electricity from the PV array into AC electricity, which can connect seamlessly to the electricity grid. Inverter efficiencies can be as high as 98.5%. Inverters also sense the utility power frequency and synchronize the PV-produced power to that frequency. When utility power is not present, the inverter will stop producing AC power to prevent “islanding,” a condition which could be dangerous to utility workers trying to fix a de-energized distribution system. This safety feature is built into all grid-connected inverters in the market.

Electricity produced from the PV system may also be fed to a step-up transformer to increase the voltage to match the grid. There are two primary types of inverters for grid-connected systems: string and micro inverters. Each type has strengths and weakness and may be recommended for different types of installations.

Wiring for Electrical Connections

Electrical connections, including wiring, disconnect switches, fuses, and breakers are required to meet electrical code (e.g., NEC Article 690) for both safety and equipment protection. In most traditional applications, wiring from (i) the arrays to inverters and (ii) inverters to point of interconnection is generally run as direct burial through trenches.

Attachment #4 – Glossary or Definition of Terms

Glossary or Definition of Terms	
PV	Photovoltaic energy
AC	Alternating current, which can be transmitted over+ power lines
DC	Direct current, which cannot be transmitted over power lines
Ballast	A footing on which a solar panel can be placed which will not penetrate the landfill cap
Inverter	A machine which takes in direct current and converts it to alternating current, which can then be transmitted to an electrical substation for transmission to a utility company
Energy Density	The amount of energy available per a given region of space (per unit volume); this is impacted by the packing factor, which is the number of solar arrays that can be placed in a specific area
kW or kWh	Kilowatt or kilowatt hours
MW or MWh	Megawatt or megawatt hours
ITC	Investment tax credits
O&M	Operations and maintenance
PPA	Power purchase agreement, which is a legal contract between an electricity provider and a purchaser that defines all commercial terms for the sale of electricity
Transformer	An electrical device used to increase or decrease the alternating voltage in electrical power applications. A transformer on a solar power facility is primarily used to step-up the voltage to deliver the renewable energy to the utility grid.
EDC	Electric Distribution Company
GIS	Geographic information Systems